

- INSTALLED BY BEST BUY CO.
- ALL WALLS AND COLUMNS TO RECEIVE 6" COVE VINYL BASE.
 PROVIDE 4'-0" FRP PANELS BEHIND

ERMI 2001

₩P

- BLOCKING AS NOTED.
- PARTITION LEGEND
- EXPOSED CONCRETE BLOCK WALL CORE FILLED WITH INSULATION INTERIOR TO
- CHAINLINK FENCE TO 10'-0" A.F.F.
 POSTS @ 6'-0" O.C. PROVIDE (2)
 DOUBLE ACTING GATES WITH PROVISIONS
 FOR 1/2" PAD LOCKS.
 BBC TO PROVIDE LOCKS.
- }" TYPE "X" GYP. BD. TO ROOF
- HEIGHT. REFER TO NOTES 1 & 3 BELOW. SAME AS 3 WITH THE ADDITION OF
- SAME AS 4 WITH 1/2" GYP. BD. OVER
 1/2" CDX PLYWOOD (FIRE TREATED
 AS REQUIRED BY CODE) IN LIEU OF
- SAME AS 4 WITH 1/2" CDX PLYWOOD (FIRE TREATED AS REQUIRED BY CODE) (FIRE TREATED AS REQUIRED BY CODE, IN LIEU OF GYP. BD. ON INTERIOR WALLS OF OFFICES (TAPE & FLOAT).

- WALLS THAT ARE FREE STANDING.
- ROOF LADDER TO HAVE OSHA APPROVED
 LADDER EXTENTION BEYOND ROOF LINE. NO
 ROOF HATCH SHALL BE WITHIN 6'-0" OF
 OUTSIDE WALL.
 PROVIDE 3/4" BC PLYWOOD OVER GYP. BD. BEHIND ROOF HATCH ACCESS LADDER

- GENERAL NOTES
- SPRINKLER RISER TO BE IN RECEIVING. ALL ROOM DIMENSIONS ARE INSIDE WALL CLEAR DIMENSIONS. ALL CASEWORK WILL BE SUPPLIED &
- ALL CASEWORK BASES TO RECEIVE " VINYL BASE. SUPPLIED AND INSTALLED BY GENERAL CONTRACTOR.
- JANITORS SINK.
- REFER TO SHEET E-2A, E-3, & E-8A TO DETERMINE LOCATION OF UNDERFLOOR CONDUIT FOR ELECTRICAL AND
- LOW VOLTAGE. 8. GENERAL CONTRACTOR TO PROVIDE
- GENERAL CONTRACTOR RESPONSIBLE TO PAINT ALL CORNER FILLERS. SEE LEGEND BELOW SYMBOL "A". 10. INSTALL VERTICAL EXPANSION JOINT MINIMAL AT COLUMN/ GRID LINES AND
- AT THE HEAD OF DOOR JAMBS / OPENINGS. TO REDUCE STRESS CRACKING. 11. GENERAL CONTRACTOR TO REFER TO SPECIFICATION FOR PAINT PROGRAM.
- BE TOOLED FOR FINISHED SURFACE TO
- 3}" STUDS @ 16" O.C. TO UNDERSIDE OF ROOF DECK. EXTEND
- 3 PECK AT JANITOR AREA.
 EXTEND 5/8" TYPE "X" GYP. BD. ON
 CEILING SIDE TO 6" ABOVE CEILING
- 3A SOUND INSULATION FROM FINISHED FLOOR TO 6" ABOVE SUSPENDED CEILING.
- }" TYPE "X" GYP. BD. ON 3}" STUD @ 16" O.C. TO 11'-6" A.F.F.
- GYP. BD. AT ROOM. SIDE OF WALL (TAPE & FLOAT).
- PLUMBING WALL WITH WATER RESISTANT GYP. BD. PER LOCAL CODES.
- 3" TYPE "X" GYP. BD. ON 6" STUD @ 16" O.C. TO UNDERSIDE OF ROOF DECK.
- SAME AS 6 WITH THE ADDITION OF CDX 3/4" PLYWOOD TO 8'-0" A.F.F. ON THE ELECTRICAL ROOM SIDE. PROVIDE FIRE TREATED PLYWOOD WHERE REQUIRED BY CODE.
- }" TYPE "X" GYP. BD. ON STAGGERED 6" STUDS @ 12" O.C. W/ WIRE MESH ON BOTH SIDES TO UNDER SIDE OF ROOF DECK. SOUND INSULATION FROM FINISHED FLOOR TO UNDERSIDE OF ROOF DECK.
- 3}" STUDS AND 3" DRYWALL 8 BOTH SIDES TO 6" ABOVE CEILING HEIGHT.
- 3}" STUDS AND }" DRYWALL (ONE SIDE) TO 6" ABOVE CEILING AND
 3/4" PLYWOOD (ELECTRICAL ROOM SIDE)
 FROM FLOOR TO 8'-0" A.F.F.
 PROVIDE FIRE TREATED PLYWOOD WHERE
 REQUIRED BY CODE.
- 11 1/4" PLENUM WALL. USE (2) ROWS OF 3 5/8" METAL STUDS @ 24" O.C. WITH 5/8" TYPE "X" GYP. BD. TO 11'-6" A.F.F. INSTALI GYP. BD. @ TOP OF PARTITION TO PROVIDE CONTINUOUS SEAL FOR PLENUM. INSIDE CLEAR DIMENSION TO BE 10" MIN.
- 3" TYPE "X" GYP. BD. ON 3}" STUD @ 16" O.C. TO 8'-0" A.F.F.
- CORNER FILLERS PROVIDED AND INSTALLED BY FIXTURE CONTRACTOR. PAINTED PT-1 BY GENERAL CONTRACTOR.

 - PROVIDE DEEP LEG TOP TRACK NOT FASTENED TO STUDS TO ALLOW FOR VERTICAL EXPANSION OF WALLS & ROOF STRUCTURE. ADDITIONALLY, PROVIDE VERTICAL EXPANSION JOINTS AS REQUIRED TO PREVENT CRACKS IN WALLS PROVIDE HORIZONTAL BRACING AT TOP OF WALLS AS NEEDED AT LOW PARTITION
- ALL WALLS TO REMAIN FACING SALES AREA NEED TO HAVE BOTH GYP. BD. & STUDS EXTENDED TO THE UNDERSIDE OF THE PROVIDÈ ADEQUATE 2X WOOD BLOCKING IN FIXTURES, PLUMBING ACCESSSORIES, ELECTRIC WATER COOLER, MILLWORK,
- ELECTRIC PANELS, ROOF ACCESS LADDER, 5. AT ALL EXPOSED CORNERS IN SALES AREA PROVIDE CORNER PROTECTORS — REFER TO INTERIOR FINISH NOTE.

05/09/01

FLOOR PLAN

03/02/01

Crawford McWilliams Hatcher

1800 International Park Drive

Birmingham, Alabama 35243 Telephone: (205) 969-2696

Architects, Inc.

Suite 300

660.30

02/21/01 MKL MKL

Sequence 04 of total